



**WMTS-101:20241**

**Appliances & commercial catering equipment (low hazard rating)**

---

**WaterMark Technical Specification**

Document formerly known as:-

ATS 5200.101 – 2005 Technical Specification for Plumbing and Drainage Products  
Appliances (low hazard rating)

Publication History:-

First published as ATS 5200.101—2005.  
Revised and redesignated as WMTS-101:2014.  
Revised as WMTS-101:2018  
Revised as WMTS-101:2021  
Revised as WMTS-101:2024

**20241**



## IMPORTANT NOTICE AND DISCLAIMER

On 25 February 2013 management and administration of the WaterMark Certification Scheme transferred to the Australian Building Codes Board (ABCB). From this date all new technical specifications will be named WaterMark Technical Specifications (WMTS). The WaterMark Schedule of Products lists all current WMTS.

~~This Technical Specification supersedes WaterMark Technical Specification WMTS 101:2018.~~

While the ABCB, the participating Governments and other groups or individuals who have endorsed or been involved in the development of the WMTS, have made every effort to ensure the information contained in this document is accurate and up to date, such information does in no way constitute the provision of professional advice.

The ABCB gives no warranty or guarantee and accepts no legal liability whatsoever arising from or connected to, the accuracy, reliability, currency or completeness of any material contained in this document.

Users should seek appropriate independent professional advice prior to relying on, or entering into any commitment based on material in this document in relation to plumbing or related activities. Its interpretation in no way overrides the approvals processes in any jurisdiction.

The ABCB welcomes suggestions for improvement in the WMTS, and encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact the ABCB via phone on 1300 134 631, email at [watermark@abcb.gov.au](mailto:watermark@abcb.gov.au) or write to the WaterMark Administering Body, ABCB, GPO Box 2013, Canberra ACT 2601.

Copyright within the following document is owned by the Australian Government and States and Territories of Australia and its Licensors.

Apart from any use permitted under the Copyright Act 1968, no part may be reproduced without prior permission. Requests and enquires concerning reproduction and rights should be directed to:

Chief Executive Officer  
Australian Building Codes Board  
GPO Box 2013  
Canberra ACT 2601  
Phone 1300 134 631 – Fax 02 6213 7287

## PREFACE

~~WaterMark Technical Specification WMTS-101:2024 Technical Specification for Appliances & commercial catering equipment was prepared by industry to supersede WMTS-101:2021. WaterMark Technical Specification WMTS-101:2021 Appliances (low hazard rating) was prepared by industry to supersede WaterMark Technical Specification WMTS-101:2018.~~

~~WaterMark Technical Specification WMTS-101:2021 Technical Specification for plumbing and drainage products, Appliances (low hazard rating), incorporates amendments to Clause 8.2, Table A1 and minor editorials.~~

The objective of this Technical Specification is to enable product certification in accordance with the requirements of the Plumbing Code of Australia (PCA).

~~The major changes to this revision are as follows:-~~

- ~~(i) Scope expansion to include commercial catering equipment.~~
- ~~(ii) Commercial catering equipment technical requirements added to body of specification.~~
- ~~(+)(iii) Inclusion of compliance Tables A3 & A4.~~

~~The objective of this revision is to remove the specific listing of individual products in the Scope, thus eliminating the need to amend the Scope for every new or innovative product that may require evaluation against this Specification. The products listed within the existing Scope and any new or innovative products will be specified within the WaterMark Schedule of Products.~~

The word 'VOID' set against a clause indicates that the clause is not used in this Technical Specification. The inclusion of this word allows a common use clause numbering system for the WaterMark Technical Specifications.

The term 'normative' has been used in this Technical Specification to define the application of the appendices to which they apply. A 'normative' appendix is an integral part of a Technical Specification.

The test protocol and information in this Technical Specification was arranged by committee members to meet the authorization requirements given in the PCA.

The WaterMark Schedule of Products and Schedule of Excluded Products are dynamic lists and change on a regular basis. These lists are located on the ABCB website ([www.abcb.gov.au](http://www.abcb.gov.au)). These lists are version controlled with appropriate historic references.



## ACKNOWLEDGEMENTS

Australian Technical Specification ATS 5200.101–2005, on which this Technical Specification is based, was prepared by Standards Australia Committee WS-031, Technical Procedures for Plumbing and Drainage Products Certification. It was approved on behalf of the Council of Standards Australia on 14 December 2004.

The following organisations were represented on Committee WS-031 in the preparation of Australian Technical Specification ATS 5200.101–2005.

- AUSTAP
- Australian Electrical and Electronic Manufacturers Association
- Australian Industry Group
- CSIRO Manufacturing and Infrastructure Technology
- Certification Interests (Australia)
- Consumer Electronics Suppliers Association
- Copper Development Centre—Australia
- Gas Appliances and Services Association
- Master Plumbers Australia
- Master Plumbers and Mechanical Services Association of Australia
- Master Plumbers, Gasfitters and Drainlayers New Zealand
- National Fire Industry Association
- New Zealand Water and Waste Association
- Plastics Industry Pipe Association of Australia
- Plumbing Industry Commission
- South Australian Water Corporation
- Water Services Association of Australia

WaterMark Technical Specification WMTS-101:20241 was prepared by industry and reviewed by the ABCB WaterMark Technical Advisory Committee. It was approved by the ABCB on TBA-23 February 2021.

## TABLE OF CONTENTS

<b>1</b>	<b>Scope .....</b>	<b>6</b>
<b>2</b>	<b>Application.....</b>	<b>6</b>
<b>3</b>	<b>Referenced documents.....</b>	<b>6</b>
<b>4</b>	<b>Definitions .....</b>	<b>7</b>
<b>5</b>	<b>Materials .....</b>	<b>8</b>
<b>6</b>	<b>Marking .....</b>	<b>8</b>
<b>7</b>	<b>Packaging .....</b>	<b>8</b>
<b>8</b>	<b>Design.....</b>	<b>8</b>
<b>9</b>	<b>Performance requirements and test methods.....</b>	<b>9</b>
<b>10</b>	<b>Test sequence and test sample plan .....</b>	<b>10</b>
<b>11</b>	<b>Product documentation .....</b>	<b>11</b>
<b>1</b>	<b>Scope .....</b>	<b>6</b>
<b>2</b>	<b>Application.....</b>	<b>6</b>
<b>3</b>	<b>Referenced documents.....</b>	<b>6</b>
<b>4</b>	<b>Definitions .....</b>	<b>7</b>
<b>5</b>	<b>Materials .....</b>	<b>7</b>
<b>6</b>	<b>Marking .....</b>	<b>7</b>
<b>7</b>	<b>Packaging .....</b>	<b>7</b>
<b>8</b>	<b>Design.....</b>	<b>8</b>
<b>9</b>	<b>Performance requirements and test methods.....</b>	<b>8</b>
<b>10</b>	<b>Test sequence and test sample plan .....</b>	<b>9</b>
<b>11</b>	<b>Product documentation .....</b>	<b>9</b>



## 1 SCOPE

This Technical Specification sets out minimum product requirements for appliances **and commercial catering equipment** connected to the water service and/or sanitary plumbing piping. Appliances covered by this Technical Specification are listed on the WaterMark Schedule of Products.

**Note 1. This Technical Specification does not cover sanitation aspects beyond the water system within the commercial catering equipment i.e. from the mains water supply connection(s) to all water use type outlets within the appliance.**

**Note 2. Products within this scope may also be a subject to other applicable regulations, e.g. electrical safety, gas safety, pressurised vessels, etc.**

## 2 APPLICATION

**ProductsAppliances** covered by this Technical Specification are those not intended to directly supply drinking water, **and where it is considered that there is low risk of contamination through back siphonage.**

This Technical Specification will be referenced on the WaterMark Certification Scheme Schedule of Products.

Appendix A sets out the means by which compliance with this Technical Specification shall be demonstrated by a manufacturer for the purpose of product certification.

## 3 REFERENCED DOCUMENTS

The following documents are referred to in this Technical Specification:

AS

1589 Copper and copper alloy waste fittings

2845.2 Water supply—Backflow prevention devices, Part 2: Air gaps and break tanks

2887 Plastic waste fittings

3688 Water supply **and gas systems—Metallic fittings and end connectorsCopper and copper alloy body compression and capillary fittings and threaded end connectors**

AS/NZS

1260 PVC-U pipes and fittings for drain, waste and vent application

2845.1 Water supply—Backflow prevention devices, Part 1: Materials, design and performance requirements

- 3499 ~~Water supply—~~Flexible ~~hose assemblies~~ ~~tube connectors for water supply~~
- 3500.0 Plumbing and drainage, Part 0: Glossary of terms
- 3500.1 Plumbing and drainage, Part 1: Water services
- 3500.2 Plumbing and drainage, Part 2: Sanitary plumbing and drainage systems
- 4020 Testing of products for use in contact with drinking water

#### EN

~~61770/ A11 Electric appliances connected to the water mains - Avoidance of back siphonage and failure of hose-sets~~

#### IEC

61770 Electric appliances connected to the water mains—Avoidance of back siphonage and failure of hose-sets

#### BS

6920–1 Suitability of non-metallic materials and products for use in contact with water intended for human consumption with regard to their effect on the quality of the water, - Part 1: Specification

#### SA(SANZ)

~~HB 18.28—Guidelines for third party certification and accreditation—Guide 28—General rules for a model third party certification system for products~~

#### NSF/ANSI

~~51 Food Equipment Material~~

61 Drinking Water System Components – Health Effects

#### NCC

PCA Plumbing Code of Australia

## 4 DEFINITIONS

For the purpose of this Technical Specification, the definitions given in AS/NZS 3500.0 apply.



## 4.1 Commercial catering equipment

Appliances and equipment used in the Foodservice Industry for preparation, cooking, storage and serving of food.

# 5 MATERIALS

VOID

# 6 MARKING

Markings to be placed on product or packaging shall be ~~Each appliance shall be permanently and legibly marked~~ in accordance with the [Manual for the WaterMark Certification Scheme](#). Additionally, each product shall be permanently and legibly marked with the backflow prevention method used to comply with clause 8.2.

e.g THIS PRODUCT INCORPORATES BACKFLOW PREVENTION COMPLYING WITH a)

# 7 PACKAGING

Products shall be packaged in such a manner so as to avoid damage and contamination during transportation and handling. VOID

# 8 DESIGN

## 8.1 End connectors

Water service connections shall be capable of making a watertight seal to a fitting end connection complying with AS 3688.

Sanitary plumbing connections shall be capable of making a watertight connection to a waste fitting complying with [the relevant applicable specification listed on the WaterMark Schedule of Products and AS/NZS 3500.2, AS 1589, AS 2887, or a sanitary plumbing pipe or fitting complying with AS/NZS 1260](#).

## 8.2 Backflow prevention

Appliances [and commercial catering equipment](#) shall—

a) ~~(a)~~ — comply with the backflow prevention requirements of IEC 61770; or

~~a)~~ b) Comply with the backflow prevention requirements of EN 61770/A11; or

~~b)~~ c) (b) — comply with the backsiphonage test of AS 2845.2:1996; or

NOTE: 8.2(b) can only be used for testing where the appliance [or commercial catering equipment](#) incorporates an air gap or a break tank incorporating an air-gap.



e)d) ~~(e)~~ be supplied with a backflow prevention device complying with AS/NZS 2845.1 and of a type required by the PCA in AS/NZS 3500.1.

Where backflow prevention devices are required to be installed external to the appliance, commercial catering equipment, or apparatus, the devices shall be supplied with the appliance and include appropriate installation instructions.

### 8.3 Water seal

If the appliance, or commercial catering equipment has an integral waste trap, the water seal shall comply with AS 1589 or AS 2887 and AS/NZS 3500.2, the relevant applicable specification listed on the WaterMark Schedule of Products and AS/NZS 3500.2

### 8.4 Electrical Safety

Electrical components of the appliance or commercial catering equipment shall comply with the relevant requirements of the electrical regulator, where required.

## 9 PERFORMANCE REQUIREMENTS AND TEST METHODS

### 9.1 Products in contact with drinking water

Products in contact with drinking water shall comply with AS/NZS 4020. Hoses shall be tested as end-of-line product.

Products shall be deemed to comply with this requirement where the volume contained in the water supply pipework up to the backflow prevention device is less than 1 L and provided that the components have been tested to a recognized Standard or International Specification that assesses the products for their effect on the quality of water, e.g. BS 6920-1 or NSF 61.

**NOTE 1:** The only products considered to be in contact with drinking water are those upstream of the backflow prevention device.

**NOTE 2:** International Specifications that assess products for their effect on the quality of water may include BS 6920-1, NSF 61 and WRAS approvals.

#### 9.1.1 Product in contact with water downstream of the backflow prevention device used directly for food preparation, e.g. cooking

Products in contact with water downstream of the backflow prevention device and up to the water outlet e.g faucet, spout, hand shower, shall be made of materials recognised by an applicable Specification or tested to a recognised Specification that assesses the products for their effect on the quality of water, as safe for food preparation.



NOTE: NSF/ANSI 51 – Food Equipment Materials is a specification that may be used to determine suitability of materials in contact with water used for food preparation.

## 9.2 Integral cleaning systems

Water supplied for integral cleaning systems within commercial catering equipment shall be downstream of the backflow prevention device and shall be separated from the water used for food preparation.

## 9.3 Cross connections

Water supplied for food preparation shall not be possible to be cross connected with any other lines, e.g. with any cleaning detergent line.

### 9.29.4 Appliance hose connections

Hoses connected to appliances or commercial catering equipment shall comply with the hose-sets requirements of AS/NZS 3499 or IEC 61770 or EN 61770/A1. This includes hoses connecting the appliance or commercial catering equipment to the main water supply and any hose outlet from the appliance or commercial catering equipment, where the hose can come under pressure by a valve operation.

e.g. a hand shower for cleaning.

### 9.39.5 Strength of assembly

When tested at twice the maximum working pressure and at the maximum working temperature, the assembly shall not leak. When tested at twice the maximum working pressure, and at the maximum working temperature, for 5 minutes, parts of the water circuit assembly subject to permanent mains supply pressure, shall not leak.

This excludes water mains supply connections directly to electromechanically controlled and normally closed valves i.e. no parts of the water circuit assembly are subject to permanent mains supply pressure.

## 9.6 Watertightness

When tested at maximum working pressure and ambient temperature, the water system shall not leak under any product operating conditions.

# 10 TEST SEQUENCE AND TEST SAMPLE PLAN

Performance tests may be completed in any sequence.

## 1011 PRODUCT DOCUMENTATION

### 10.111.1 Product data

Product data, which identifies critical product characteristics as follows, shall be available:

a) Drainage requirements including size and position of piping.

b) Maximum water supply temperature, pressure and flow rate.

NOTE: Some products may not have a maximum flow rate requirement.

c) Minimum water supply quality.

NOTE 1: Water quality may include pH, hardness, conductivity and chlorine levels.

NOTE 2: Some products may not have a minimum water supply quality requirement.

d) Maximum waste discharge temperature in degrees Celsius (C°).

e) Backflow prevention method used to comply with clause 8.2 shall be included on the Certificate of Conformity.

Product data, which identifies critical product characteristics such as follows, shall be available:

(a) Drainage requirements including size and position of piping.

(b) Water supply temperature and pressure limitations.

The backflow prevention method used to comply with clause 8.2 shall be included on the Certificate of Conformity.

### 10.211.2 Installation instructions

Detailed installation instructions shall be provided, which shall include the following:

- (a) References to installation in accordance with the PCA, including any limitations on the product.

NOTE: A product that is listed on the WaterMark Product Database and is marked in accordance with the WaterMark Certification Scheme is recognised by authorities having jurisdiction as being authorised for use in a plumbing or drainage installation. This is because the product complies with the applicable product specification. The installation of an authorised product must meet the requirements of the PCA. Where the PCA does not contain installation requirements applicable to the authorised product, acceptance of the installation is at the discretion of the authority having jurisdiction.

- (b) Step-by-step instructions.

- (c) Commissioning procedures and adjustments required.



- (d) Troubleshooting guide.
- (e) Contact details for after-sales service.

DRAFT

## APPENDIX A - MEANS FOR DEMONSTRATING COMPLIANCE WITH THIS TECHNICAL SPECIFICATION

(Normative)

### A.1 SCOPE

This Appendix sets out the means by which compliance with this Technical Specification is to be demonstrated by a manufacturer under the WaterMark Certification Scheme.

### A.2 RELEVANCE

The long-term performance of plumbing systems is critical to the durability of building infrastructure, protection of public health and safety, and protection of the environment.

### A.3 PRODUCT CERTIFICATION

The purpose of product certification is to provide independent assurance of the claim by the manufacturer that products comply with this Technical Specification.

The certification scheme serves to indicate that the products consistently conform to the requirements of this Technical Specification.

The sampling and testing plan, as detailed in Paragraph A5 and Table A1, shall be used by the WaterMark Conformity Assessment Body. Where a batch release testing program is required it shall be carried out by the manufacturer as detailed in Paragraph A5.

### A.4 DEFINITIONS

#### A.4.1 Batch release test

A test performed by the manufacturer on a batch of components, which has to be satisfactorily completed before the batch can be released.

#### A.4.2 Production batch

Clearly identifiable collection of units, manufactured consecutively or continuously under the same conditions, using material or compound to the same specification.

#### A.4.3 Sample

One or more units of product drawn from a batch, selected at random without regard to quality.

NOTE: The number of units of product in the sample is the sample size.



#### **A.4.4 Sampling plan**

A specific plan that indicates the number of units of components or assemblies to be inspected.

#### **A.4.5 Type test batch**

Schedule of units of the same type, identical dimensional characteristics, all the same nominal diameter and wall thickness, from the same compound. The batch is defined by the manufacturer.

#### **A.4.6 Type testing (TT)**

Testing performed to demonstrate that the material, component, joint or assembly is capable of conforming to the requirements given in the Technical Specification.

### **A.5 TESTING**

#### **A.5.1 Type testing**

Table A1 sets out the requirements for type testing and frequency of re-verification.

#### **A.5.2 Batch release testing**

Where third-party certification requires a batch release test program it shall be established between the manufacturer and the WaterMark Conformity Assessment Body.

NOTE: See HB 18.28 for guidelines for third-party certification and accreditation.

#### **A.5.3 Retesting**

In the event of a test failure, the products within the batch shall be tested at an appropriate acceptable quality level (AQL) and only those batches found to comply may be claimed and/or marked as complying with this Technical Specification.

**Table A1—TYPE TESTS**

Characteristic	Clause	Requirement	Test method	Frequency
Marking	6	Marking	Visual inspection	At any change of the marking process or requirements
Design	8.1	End connectors	Design review	At any change of design
	8.2	Backflow protection	Clause 8.2	
Performance	9.1	Products in contact with drinking water	AS/NZS 4020 or Clause 9.1	
	9.2	Hose sets	AS/NZS 3499 or IEC 61770	
	9.3	Strength of assembly	Clause 9.3	
Product documentation	11	Installation instructions	Visual inspection	At any change of installation or operation specification

**TABLE A1  
TYPE TESTS**

Characteristic	Clause	Requirement	Test method	Frequency
Marking	6	Marking	Visual inspection	At any change of the marking process or requirements
Design	8.1	End connectors	Design review	At any change of design
	8.2	Backflow protection		
	8.3	Water seal		
Performance	9.1	Products in contact with drinking water	AS/NZS 4020 or Clause 9.1	At any change of design or materials specification or on renewal of certification whichever occurs first
	9.1.1	Products in contact with water used directly in food preparation	Recognised specification or Clause 9.1.1	
	9.4	Hose sets	AS/NZS 3499 or IEC 61770 or EN 61770/A11	
	9.5	Strength of assembly	Clause 9.5	



Characteristic	Clause	Requirement	Test method	Frequency
Product documentation	11	Installation instructions	Visual inspection	At any change of installation or operation specification

DRAFT



**TABLE A2**  
**BATCH RELEASE TESTS**

Characteristic	Clause	Requirement	Test method	Frequency
Marking	6	Marking	Visual inspection	Each unit
Design	8.1	End connectors	Visual inspection	Once per batch
	8.2	Backflow protection		
	8.3	Water seal		
Performance	9.6	Watertightness	Visual inspection	Once per batch
Product documentation	11	Installation instructions supplied with appliance	Visual inspection	Each unit

**TABLE A3**  
**MINIMUM ANNUAL INSPECTION REQUIREMENTS**

Characteristic	Clause	Requirement	Verification method	Frequency
Marking	6	Marking	Visual inspection	Sample from product family, covering all families within 5 year certification cycle
Design	8.1	End connectors	Visual inspection	
	8.2	Backflow protection		
	8.3	Water seal		
Product documentation	11	Installation instructions supplied with appliance	Visual inspection	



**TABLE A4**  
**RE-EVALUATION TESTING**

Characteristic	Clause	Requirement	Test method
Marking	6	Marking	Visual inspection
Design	8.1	End connectors	Design review
	8.2	Backflow protection	Design review
	8.3	Water seal	Design review
Performance	9.1	Products in contact with drinking water	AS/NZS 4020 or Clause 9.1
	9.1.1	Products in contact with water used directly in food preparation	Recognised specification or Clause 9.1.1
	9.4	Hose sets	AS/NZS 3499 or IEC 61770
	9.5	Strength of assembly	Clause 9.5
Product documentation	11	Installation instructions	Visual inspection