



WMTS-535:2021

Air valves for plumbing applications

WaterMark Technical Specification

Publication History:-

First published as WMTS-535:2021

2021

IMPORTANT NOTICE AND DISCLAIMER

While the ABCB, the participating Governments and other groups or individuals who have endorsed or been involved in the development of the WaterMark Technical Specification (WMTS) have made every effort to ensure the information contained in this WMTS is accurate and up to date, such information does not in any way constitute the provision of professional advice.

The ABCB gives no warranty or guarantee and accepts no legal liability whatsoever arising from or connected to, the accuracy, reliability, currency or completeness of any material contained in this WMTS.

Users should seek appropriate independent professional advice prior to relying on, or entering into any commitment based on material in this WMTS in relation to plumbing or related activities. Its interpretation in no way overrides the approvals processes in any jurisdiction.

The ABCB welcomes suggestions for improvement in the WMTS and encourages readers to notify it immediately of any apparent inaccuracies or ambiguities. Contact the WaterMark Administering Body via phone on 1300 134 631, email at watermark@abcb.gov.au, or write to GPO Box 2013, Canberra ACT 2601.

© Australian Government and States and Territories of Australia 2021

This work is copyright. Apart from any use as permitted under the Copyright Act 1968, no part may be reproduced by any process without prior written permission from the Commonwealth and State and Territory Governments of Australia. Requests and inquiries concerning reproduction and rights should be addressed to the:

Chief Executive Officer
Australian Building Codes Board
GPO Box 2013
Canberra ACT 2601

Phone 1300 134 631
watermark@abcb.gov.au

PREFACE

This WaterMark Technical Specification (WMTS) was prepared in accordance with the Manual for the WaterMark Certification Scheme, Appendix 4, Protocol for Developing Product Specifications.

The objective of this WaterMark Technical Specification is to enable product certification in accordance with the requirements of the Plumbing Code of Australia (PCA).

The word 'VOID' set against a clause indicates that the clause is not used in this WaterMark Technical Specification. The inclusion of this word allows a common use clause numbering system for the WaterMark Technical Specifications.

The term 'normative' has been used in this WaterMark Technical Specification to define the application of the appendices to which they apply. A 'normative' appendix is an integral part of a WaterMark Technical Specification.

The test protocol and information in this WaterMark Technical Specification was arranged to meet the authorisation requirements given in the PCA.

The WaterMark Schedule of Products and the WaterMark Schedule of Excluded Products are dynamic lists and change on a regular basis. Based on this function, these schedules are now located on the ABCB website (www.abcb.gov.au). These lists will be version controlled with appropriate historic references.

ACKNOWLEDGEMENTS

WaterMark Technical Specification WMTS-535:2021 was prepared by industry and was approved by the Administering Body on **XX Month 2021**.

TABLE OF CONTENTS

1	Scope	1
2	Application.....	1
3	Referenced documents.....	1
4	Definitions	2
5	Materials	2
6	Marking	2
7	Packaging	2
8	Design	3
9	Performance criteria and test methods	3
10	Test sequence and test sample plan	3
11	Product documentation	3
Appendix A	Means for demonstrating compliance with this Specification	5

1 SCOPE

This specification includes requirements for air valves for plumbing applications. The air valves covered by this specification are limited to anti-slam valves within the scope of AS 4956. Additionally, air valves for plumbing applications are limited to the requirements of this specification. This specification is applicable to anti-slam air valves from DN 15 to DN 250, with a maximum operating temperature of 70°C.

2 APPLICATION

The intended application of air valves is within hot, cold and heated recirculatory building plumbing pipe systems. The primary function of the valve is to keep entrapped air out of the building pipework network, to maximise flows and minimise water hammer within the pipework.

Appendix A sets out the means by which compliance with this specification shall be demonstrated by a manufacturer for the purpose of product certification.

3 REFERENCED DOCUMENTS

AS

- 1565 Copper and copper alloys - Ingots and castings
- 4956 Air Valves for water supply

AS/NZS

- 1567 Copper and Copper alloys – Wrought rods, bars and sections
- 1568 Copper and copper alloys - Forging stock and forgings
- 4020 Testing of products for use in contact with drinking water
- 3500.0 Plumbing and drainage, Part 0: Glossary of terms.

CEN/TS

- 13388 Copper and copper alloys - Compendium of compositions and products

NCC

- PCA Plumbing Code of Australia

4 DEFINITIONS

For the purpose of this specification, the definitions given in the WaterMark Scheme Rules, Plumbing Code of Australia, AS/NZS 3500.0 and those below apply.

4.1 Anti-slam air valve

A valve fitted with anti-slam devices, which allows air to be released through an orifice at a controlled rate, to reduce the impact of pressure surges that may occur during filling of the pipework or when the water column has been separated and is re-joining.

5 MATERIALS

5.1 General

The materials used in the construction of air valves shall comply with AS 4956.

5.2 Materials in contact with drinking water

Materials in contact with drinking water shall comply with AS/NZS 4020. Products shall be tested using a maximum scaling factor of 0.05.

5.3 Copper Alloys

Copper alloys shall comply with AS 4956, or CEN/TS 13388 and be compliant to AS 2345.

6 MARKING

Markings to be placed on products or packaging shall, as a minimum, be in accordance with clause 9.6 of the [Manual for the WaterMark Certification Scheme](#).

The marking of air valves shall comply with AS 4956.

In addition to the marking requirements of AS 4956, an indicator to illustrate the product installation in a vertical orientation shall be marked on the product.

7 PACKAGING

The packaging of air valves shall comply with AS 4956

8 DESIGN

8.1 General

The design of air valves in scope shall comply with the design requirements of AS 4956. Air valves shall be anti-slam type only.

8.2 Protective coatings

Coatings applied to air valves shall comply with AS 4956 – Protective Coatings.

8.3 Strainers

Air valves shall incorporate design features that prevent the fouling of the valve due to debris in the water supply. Mesh strainers that are accessible for the purposes of cleaning, are considered suitable means to prevent debris entering the valve.

8.4 Provision for drainage

Air valves shall incorporate means to connect the discharge to the building drainage system. End Connections for the connection to the drainage system shall comply with AS 4956.

9 PERFORMANCE CRITERIA AND TEST METHODS

9.1 General

Air valves shall comply with the performance requirements of AS 4956.

10 TEST SEQUENCE AND TEST SAMPLE PLAN

Type testing shall be completed in accordance with the sampling requirements of AS 4956.

11 PRODUCT DOCUMENTATION

The following documents shall be supplied with the product:

- a) Installation, operating and maintenance instructions.
- b) The installation instructions shall reference installation in accordance with the NCC Volume Three – Plumbing Code of Australia, and any limitations on the product.

Note: A material or product that is listed on the WaterMark Product Database and is marked in accordance with the WaterMark Certification Scheme is recognised by authorities having jurisdiction as being authorised for use in a plumbing or drainage installation. This is because the material or product complies with the applicable product specification. The installation of an authorised material or product must meet the requirements of the PCA.

- c) A statement that the product shall only be installed in a vertical orientation.
- d) A statement that the product shall be installed in a location that is not subject to submersion.
- e) A statement that the product shall be installed in an accessible location.
- f) A statement that the product shall be installed directly downstream of a suitable isolating valve.
- g) Information to ensure the installer is aware of the requirements for the prevention of water contamination due to cross-connection with drainage pipework.

Note: The use of a tundish in conjunction with drainage pipework should be clearly detailed in the product installation instructions.

- h) The expected flow from the valve discharge to be provided to allow the design of drainage pipework.
- i) The need for appropriate pipe supports associated with valve.
- j) The expectations of the installer during pressure testing of pipework i.e. to remove the valve or any other precautions.
- k) Product data.

All documentation shall be written in clear, concise, plain English supported by relevant figures and diagrams. Documentation may be provided in either hard copy or electronic form, e.g. installation DVDs or hyperlinks to information that may be downloaded from a website.

APPENDIX A MEANS FOR DEMONSTRATING COMPLIANCE WITH THIS SPECIFICATION

(Normative)

A.1 SCOPE

This appendix sets out the means by which compliance with this specification shall be demonstrated by a manufacturer under the WaterMark Certification Scheme.

A.2 RELEVANCE

The long-term performance of plumbing systems is critical to the durability of building infrastructure, protection of public health and safety, and protection of the environment.

A.3 PRODUCT CERTIFICATION

The purpose of product certification is to provide independent assurance of the claim by the manufacturer that products comply with this specification.

The WaterMark Certification Scheme serves to indicate that the products consistently conform to the requirements of this specification.

The sampling and testing plan, as detailed in Paragraph A5 and Table A1, shall be used by the WaterMark Conformity Assessment Body. Where a batch release testing program is required, it shall be carried out by the manufacturer as detailed in Paragraph A5 and Table A2. Minimum annual inspection requirements, as detailed in Paragraph A5 and Table A3, shall be used by the WaterMark Conformity Assessment Body for annual product conformity surveillance. Re-evaluation testing, as detailed in Paragraph A5 and Table A4, shall be used by the WaterMark Assessment Body in conjunction with renewal of the certification.

Annual product conformity surveillance shall be undertaken by the WaterMark Conformity Assessment Body in accordance with Paragraph A5 and Table A3. Re-evaluation testing for re-certification, as detailed in Paragraph A.5 and Table A4, shall be used by the WaterMark Conformity Assessment Body.

A.4 DEFINITIONS

A.4.1 Batch release test

Testing performed by the manufacturer on a batch of components, which has to be satisfactorily completed before the batch can be released.

A.4.2 Product inspection

Examination of certified product, conducted during annual product conformity surveillance, to determine its conformity with the specific requirements of its current certification and WaterMark Licence.

A.4.3 Production batch

A clearly identifiable collection of units, manufactured consecutively or continuously under the same conditions, using material or compound to the same specification.

A.4.4 Re-evaluation testing

Testing carried out in conjunction with renewal of the certification.

A.4.5 Sample

One or more units of product drawn from a batch, selected at random without regard to quality.

NOTE: The number of units of product in the sample is the sample size.

A.4.6 Sampling plan

A specific plan that indicates the number of units of components or assemblies to be inspected.

A.4.7 Type test batch

Schedule of units of the same type, identical dimensional characteristics, all the same nominal diameter and wall thickness, from the same compound. The batch is defined by the manufacturer.

A.4.8 Type testing (TT)

Testing performed to demonstrate that the material, component, joint or assembly is capable of conforming to the requirements given in the specification.

A.5 TESTING AND INSPECTION**A.5.1 Type testing**

Table A1 sets out the requirements for type testing and frequency of re-verification.

A.5.2 Batch release testing

Table A2 sets out the minimum sampling and testing frequency plan for a manufacturer to demonstrate compliance of product(s) to this specification on an ongoing basis. However, where the manufacturer can demonstrate adequate process control to the certifying body, the

frequency of the sampling and testing nominated by the manufacturer's quality plan and/or documented procedures shall take precedence for the purposes of WaterMark product certification.

A.5.3 Retesting

In the event of a batch release test failure, the products within the batch may be retested at a frequency agreed to with the WaterMark Conformity Assessment Body and only those batches found to comply may be claimed and/or marked as complying with this specification.

A.5.4 Minimum annual inspection requirements

Table A3 sets out the minimum annual inspection requirements to be undertaken.

A.5.5 Re-evaluation testing

Table A4 sets out the requirements for re-evaluation testing.

**TABLE A1
TYPE TESTS**

Characteristic	Clause	Requirement	Test method	Frequency
Materials	5.1	General – AS 4956	Review materials parts lists and compliance certificates	At any change in materials specification
	5.2	Materials in contact with drinking water	AS/NZS 4020	At any change in materials, formulation or design, or every five years, whichever occurs first
	5.3	Copper alloys	Review materials parts lists and compliance certificates	At any change in materials specification
Design	8.1	General	AS 4956	At any change in the design
	8.2	Protective coatings	AS 4956	
	8.3	Strainers	Review materials parts lists and compliance certificates	
	8.4	Provision for drainage	Design drawings and AS 4956 End connection	
Performance	9.1	Anti-slam valves	AS 4956	At any change in design or manufacturing process
Product documentation	11	Product data/Installation and maintenance instructions	Product documentation	At any change to installation requirements

TABLE A2
BATCH RELEASE TESTS

Characteristic	Clause	Requirement	Test method	Frequency
Materials	5.1	Composition, temper, etc.	Review materials parts lists and compliance certificates	Once per batch
Marking	6	Marking	Visual examination	100%
Design	8.1	AS4956 – Production tests	AS4956 – Production tests	Once per batch
Performance	9.1	AS4956 – Production tests	AS4956 – Production tests	Each valve

TABLE A3
MINIMUM ANNUAL INSPECTION REQUIREMENTS

Characteristic	Clause	Requirement	Verification method	Frequency
Design, assembly and component	8.1	General operation	Visual and component examination	Sample from product family, covering all families within 5 year certification cycle
	8.1	Inlet and outlet connections	Visual and component examination	
	8.2	Strainers	Visual and component examination	
Dimensional inspection	9.1	Anti-slam valves	Production test records	
Product marking	6	Product marking, use of the WaterMark logo and licence number	Visual inspection of marked product, relevant packaging and documentation	
Product documentation	11	Product data/Installation and maintenance instructions	Product documentation	

**TABLE A4
RE-EVALUATION TESTING**

Characteristic	Clause	Requirement	Test method
Materials	5.1	Materials	Review materials parts lists and compliance certificates
	5.2	Materials in contact with water	AS/NZS 4020
Design	8.2	End connections	AS 4956
Performance	9.1	Anti-slam valves production tests	AS 4956
Product documentation	11	Product data/Installation and maintenance instructions	Product documentation